



Certificate number: 2211701 (3)

Issued 23/01/2024

Expires 02/11/2027

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Tricel (Weston) Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:

Tricel (Weston) Ltd
Winterstoke road
Weston-super-mare
BS24 9AN
United Kingdom



KUKreg4

Product Certificate

Appendix to Certificate number: 2211701

The following products belong to this certificate

<p>PRODUCT DESCRIPTION Range of GRP sectional cold water storage cisterns. Supplied with a screened vent and overflow. Fitted with stainless steel bolts and larger cisterns are fitted with stainless steel tie bars. A float operated inlet valve is not supplied as part of this approval. ATS3 – Without Production Surveillance.</p>
<p>MODEL(S) Metric Series GRP.</p>
<p>SIZE: 500 to 1,300,000 litres.</p>
<p>SCOPE: Manufacturer recommended maximum operating temperature: Cold water use only. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only.</p>
<p>MARKING Dewey Waters, address, telephone No, model, capacity, date and other technical information. Models sold after December 2023 – Tricel, address, telephone No, model, capacity, date and other technical information.</p>
<p>MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.</p>
<p>BACKFLOW PROTECTION NOTES N/A.</p>
<p>ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.</p> <p>Every storage cistern, except one supplying water to the primary circuit of a heating system, shall be fitted with a servicing valve on the outlet pipe (s).</p> <p>A servicing valve shall be installed on the supply to the fitting in a readily accessible location. Float-controlled valves or equivalent inlet devices should be securely and rigidly attached to the cistern and installed so that the valve closes when the level of the water is not less than 25 mm below the overflowing level of the cistern. Where the cistern is fitted with an approved alternative to a warning pipe, such as an indicator instrument or visual or audible alarm, the inlet valve is to close when the water level is not less than 50 mm below the overflowing level of the cistern.</p>

Extra Notes