

Certificate of Product Approval

Certificate Number: 135c

Issue: 03

Tricel (Weston) Limited

Winterstoke Road
Weston-Super-Mare
Somerset
BS24 9AN
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Fire Sprinkler Tank

(refer to attached appendix for details)

Standards

LPS 1276: Issue 2.0

Requirements for the LPCB Certification and Listing of above Ground Suction Tanks for Sprinkler Systems

This certificate and appendix is maintained and held in force through regular surveillance activities

S.A. Colwell

Signed for BRE Global Ltd.

Sarah Colwell

Verifier

20 February 2024

Date of Issue

11 May 2022

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 135c Tricel (Weston) Limited

Issue: 03

Sectional GRP Tank

Product Name	Description	LPCB Ref. No.
Type T1 and T2 Tanks	Hot pressed moulded sectional GRP tanks.	135c/01

Notes:

All Tanks to comply with requirements below:

Design Manual	ACL0820005 Review of Dewey Waters Ltd Sectional GRP Tanks against LPS1276 Rev 2.0 regulations
Product	T1 and T2 tanks
Maximum Volume	1300m ³
Maximum Height	T1 tank 3m, T2 tank 4m
Maximum Length	40m
Maximum Width	40m
Geometric limitations	Rectangular only
Minimum environmental operating temperature	4°C
Maximum environmental operating temperature	35°C
Maximum operating wind speed	45m/s
Seismic design details	as defined within design manual
Snow loading	0.75kN/m ²
Approved territory for supply and installation	UK only installation; by directly employed Dewey staff and/or Dewey managed outsourced installation teams.

This certificate and appendix is maintained and held in force through regular surveillance activities

S. A. Colwell

Signed for BRE Global Ltd.

Sarah Colwell

Verifier

20 February 2024

Date of Issue

11 May 2022

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre