

## Certificate of Product Approval

Certificate Number: 135c

Issue: 04

### Tricel (Weston) Limited

Winterstoke Road  
Weston-Super-Mare  
Somerset  
BS24 9AN  
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Fire Sprinkler Tank

(refer to attached appendix for details)

#### Standards

##### LPS 1276: Issue 2.0

Requirements for the LPCB Certification and Listing of above Ground Suction Tanks for Sprinkler Systems

This certificate and appendix is maintained and held in force through regular surveillance activities

Signed for BRE Global Ltd.

Tony Baker

Verifier

22 March 2024

Date of Issue

11 May 2022

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 135c Tricel (Weston) Limited

Issue: 04

### Sectional GRP Tank

Product Name	Description	LPCB Ref. No.
Type T1 and T2 Tanks	Hot pressed moulded sectional GRP tanks.	135c/01

#### Notes:

All Tanks to comply with requirements below:

<b>Design Manual</b>	ACL0820005 Review of Dewey Waters Ltd Sectional GRP Tanks against LPS1276 Rev 2.0 regulations
<b>Product</b>	T1 and T2 tanks
<b>Maximum Volume</b>	1300m <sup>3</sup>
<b>Maximum Height</b>	T1 tank 3m, T2 tank 4m
<b>Maximum Length</b>	40m
<b>Maximum Width</b>	40m
<b>Geometric limitations</b>	Rectangular only
<b>Minimum environmental operating temperature</b>	4°C
<b>Maximum environmental operating temperature</b>	60°C (Note: Maximum local installation temperature 50°C)
<b>Maximum operating wind speed</b>	45m/s
<b>Seismic design details</b>	as defined within design manual
<b>Snow loading</b>	0.75kN/m <sup>2</sup>
<b>Approved territory for supply and installation</b>	UK and GCC only installation; by directly employed Tricel (Weston) Limited staff and/or Tricel (Weston) Limited managed outsourced installation teams.

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Tony Baker

Verifier

22 March 2024

Date of Issue

11 May 2022

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

